

適合性同等検査合格書

Statement of Conformity Assessment

電気用品安全法第8条第1項に規定する技術基準及び同法第9条第2項の経済産業省令で定める基準（法第9条第1項第2号に係る検査に係るものに限る）に適合していることを証明します

I hereby certify that the product mentioned below complies with the technical requirements stipulated in Paragraph 1 of Article 8 of Electrical Appliance and Material Safety Law (hereunder referred to as the Law) and the requirements defined by the ordinance of the Ministry of Economy, Trade and Industry based on Paragraph 2 of Article 9 of the Law (limited to Item 2 of Paragraph 1 of Article 9 for Inspection of the Law).

1. 合格書番号: JET0670-43004-1003
Statement Number
2. 交付年月日: 平成24年 1月20日
Effective Date January 20, 2012
3. 有効年月日: 平成31年 1月19日
Date of Validity January 19, 2019
4. 申込者名 (Applicant)
住 所: WAERNDORFERSTRASSE 3 A-2525 GUENSELSDORF, AUSTRIA
Address

氏名又は名称: FELLER GMBH
Name

5. 特定電気用品名: コードコネクターボディ
Name of Product Cord connector bodies
6. 型式の区分: 別紙のとおり
Type Classification See attached "Type Classification"
7. 製造工場名 (Manufacturer)
住 所: WAERNDORFERSTRASSE 3 A-2525 GUENSELSDORF, AUSTRIA
Address

氏名又は名称: FELLER GMBH
Name

8. 適用試験規格: 電気用品の技術上の基準を定める省令第1項
Applied Standard for Testing Article 1 of The Technical Requirements of the METI Ordinance
別表第四 1 及び 6

Appendix 4 Section 1 and Section 6

9. 適合性検査の方法: (Testing Method for Conformity Assessment)

- 1) 試験用の特定電気用品については、電気用品の技術上の基準を定める省令に定める方法

With respect to testing for Category A products, the testing method is based on the technical requirements of the Electrical Appliance and Material Safety Law stipulated in the METI Ordinance.

- 2) 当該特定電気用品に係る届出事業者又は事業場における検査設備については、電気用品安全法施行規則別表第四の検査設備の欄に掲げる検査設備ごとにそれぞれ同表の技術上の基準の欄に掲げる方法

With respect to inspection facilities required for Category A products at the factory, Testing Method described in the column of the technical requirements for each inspection facilities in the column of inspection facilities in the Appendix 4 of Enforcement Regulations of the Law.

一般財団法人 電気安全環境研究所
Japan Electrical Safety & Environment technology Laboratories (JES)

理事長 末廣 恵雄
President Shigeo Suehiro

東京都渋谷区代々木5-14-12 (5-14-12, Yoyogi, Shibuya-ku, Tokyo)

適合性同等検査合格書別紙

Statement of Conformity Assessment

型式の区分

Type Classification

要素 Factor	区分 Classification
定格電圧 Rated voltage	(1) 125V 以下のもの 125V or less
定格電流 Rated current	(4) 10A を超え 15A 以下のもの Exceeding 10A, and less than or equal to 15A
極の数 (技術基準省令別表第四 6 (1) ニ (ホ) b に定める寸法に適合するものの場合に限る。) Number of poles (limited to those specified in sub-clause 6.1.4(5)b of Appendix 4 based on the METI ordinance No. 85 in 1962)	(2) アース極を含めて 3 のもの Three including earth
接続の方式 Connection method	(1) 差込み型のもの (ロックナット式のものを除く。) Plug-in type (excluding those with locking nuts)
主絶縁体の材料 Insulation materials	(1) 合成樹脂のもの Plastic
外郭の材料 Outer case materials	(2) 合成樹脂のもの Plastic
スイッチ Switch	(2) ないもの Without switch
電線と器体との一体成形 (コンセントの場合を除く。) Non-rewirable construction (except socket outlets)	(1) あるもの With non-rewirable construction
防水構造 Type of waterproof	(3) 非防水型のもの Not treated with waterproof type

合格書番号 : J E T 0 6 7 0 - 4 3 0 0 4 - 1 0 0 3